



NOTE:

1. ALL PRIMARY CONDUIT 45° & 90° ELBOWS SHALL BE PVC EXCEPT AT POLE RISER (RIGID).
2. CONCRETE MIX SHALL BE AT LEAST 3500 PSI.
3. PAD SHALL BE 25' FROM WINDOW, DOOR OR COMBUSTIBLE MATERIAL.
4. LOCATE AREA TO BE BLOCKED OUT PER DIMENSIONS SHOWN.
5. ALL PRIMARY SHALL BE 4' DEEP.
6. PAD FORMS MUST BE APPROVED BEFORE POURING (CALL 615-893-5514)

MURFREESBORO ELECTRIC DEPARTMENT
MURFREESBORO, TENNESSEE

DETAIL SPECIFICATIONS FOR
SINGLE PHASE PAD MOUNT TRANSFORMER

25 KVA-167 KVA